

## Attachment J: Access to Humboldt County Programs Housed in Others' Facilities

Please Note: Paragraph 47 of the Consent Decree requires that, within nine months of entry of this Consent Decree, the County provide signage as necessary to comply with 28 C.F.R. § 35.163(b), after having surveyed all facilities that are the subject of this Consent Decree for the purpose of identifying those that have multiple entrances not all of which are accessible.

The technical requirements and, where appropriate, the scoping requirements of the 2010 ADA Standards are used as a guide for determining whether a program or activity held in an existing facility is “readily accessible to and usable by” persons with disabilities and for determining what changes are necessary to make this program or activity accessible if it continues to be provided in the existing facility in question. *See* 28 C.F.R. §§ 35.150(b)(1), 35.151. The term “Standards” refers to the 2010 ADA Standards for Accessible Design (28 C.F.R. § 35.104 (Title II) (defining the “2010 Standards” as the requirements set forth in appendices B and D to 36 C.F.R. part 1191 and the requirements contained in 28 C.F.R. § 35.151.)). All citations are to the Standards, unless otherwise noted.

1. In order that the following programs, services, and activities, when viewed in their entirety, will be made accessible to persons with disabilities, the County will take the following actions:
2. Within 9 months of entry of the Consent Decree, the County will complete the following modifications to **Public Health MCAH** (Altered) located at 317 2<sup>nd</sup> Street in Eureka.
  - a. Parking (owned by City)
    - i. No designated van accessible parking space is provided. Provide a van accessible parking space that is a minimum of 132 inches wide and served by an access aisle at least 60 inches wide, or a minimum of 96 inches wide and served by an access aisle at least 96 inches wide; and designated by a vertical sign with the International Symbol of Accessibility and an additional “van accessible” sign mounted at least 60 inches high to the bottom of the signs (unless there are 4 or fewer total parking spaces, in which case, signage is not required). The space and access aisle shall contain no changes in level, with slopes and cross-slopes not exceeding 2.08%, and shall have surfaces that are firm, stable, and slip-resistant; and the access aisle shall be marked so as to discourage parking in it. Standards §§ 208, 302, 502.
  - b. Offices
    - i. The meeting room and office doors have knob hardware. Provide a door with hardware, mounted between 34 and 48 inches high, that is operable with one hand and does not require tight grasping, pinching, or twisting of the wrist and requires no more than 5 pounds of force to operate. Lever-operated mechanisms, push-type mechanisms, and U-shaped handles are

acceptable designs. Standards §§ 206.4, 206.5, 309.4, 404.2.7.

c. Unisex Single User

- i. The toilet room sign is not mounted on the wall adjacent to the latch side of the door. Provide a toilet room sign with raised and Braille characters. Tactile signs shall be mounted on the wall adjacent to the latch side of the door or the nearest adjacent wall (except that signs can be mounted on the push side of doors with closers and without hold-open devices); mounted 48 inches minimum from floor to the baseline of the lowest tactile character and 60 inches maximum from the floor to the baseline of the highest tactile character; and located so that a clear floor space of at least 18 inches by 18 inches, centered on the tactile characters, is provided beyond the arc of any door's swing between the closed and 45 degrees open positions. If not all toilet rooms are accessible, provide signage with the International Symbol of Accessibility at all accessible toilet rooms. Standards §§ 216.2, 703.
- ii. The door to the toilet room has 11 inches of clear floor space on the latch side in the pull direction. Provide maneuvering clearance at least 60 inches deep perpendicular to the doorway and at least 18 inches wide parallel to the doorway on the latch side. Standards §§ 206.5, 404.2.4.1.
- iii. No accessible mirror is provided. Provide at least one mirror such that, if it is mounted above a lavatory or countertop, it is mounted with the bottom edge of the reflecting surface no more than 40 inches high; or, if it is not mounted above a lavatory or countertop, it is mounted with the bottom edge of the reflecting surface no more than 35 inches high. Standards §§ 213.2, 603.3.
- iv. The toilet seat cover dispenser controls are mounted at 47 inches above the finished floor over an obstruction. Operable parts and controls of this element shall be no more than 48 inches high for a forward reach, or no more than 44 inches high if over an obstruction between 20 and 25 inches deep (for a forward reach, obstructions may not be deeper than 25 inches and obstructions must allow knee space); or mounted not more than 48 inches high for a side reach, or no more than 46 inches high if over an obstruction between 10 and 24 inches deep (for a side reach, obstructions may not be deeper than 24 inches); and accompanied by clear floor space of 30 inches by 48 inches that allows a forward or parallel approach, respectively, by a person using a wheelchair. Standards §§ 205.1, 305, 308.2, 308.3.
- v. The toilet has insufficient clear floor space. Provide clearance at the toilet that is at least 60 inches wide and 56 inches deep. This clearance may overlap with the toilet, grab bars, dispensers, sanitary napkin disposal, coat

hooks, shelves, accessible routes, clear floor space and clearances for other fixtures, and turning space; but no other fixtures or obstructions, including lavatories, may be located within this clearance. Standards §§ 213.3.2, 604.3.

3. Within 15 months of entry of the Consent Decree, the County will complete the following modifications to the **Social Services Branch** (Altered) located at 808 E Street in Eureka.

a. Parking

i. No designated van accessible parking space is provided. Provide a van accessible parking space that is a minimum of 132 inches wide and served by an access aisle at least 60 inches wide, or a minimum of 96 inches wide and served by an access aisle at least 96 inches wide; and designated by a vertical sign with the International Symbol of Accessibility and an additional “van accessible” sign mounted at least 60 inches high to the bottom of the signs (unless there are 4 or fewer total parking spaces, in which case, signage is not required). The space and access aisle shall contain no changes in level, with slopes and cross-slopes not exceeding 2.08%, and shall have surfaces that are firm, stable, and slip-resistant; and the access aisle shall be marked so as to discourage parking in it. Standards §§ 208, 302, 502.

b. Offices

i. The door to Meeting Room #34 has knob hardware. Provide a door with hardware, mounted between 34 and 48 inches high, that is operable with one hand and does not require tight grasping, pinching, or twisting of the wrist and requires no more than 5 pounds of force to operate. Lever-operated mechanisms, push-type mechanisms, and U-shaped handles are acceptable designs. Standards §§ 206.4, 206.5, 309.4, 404.2.7.

ii. The door to Psych Counseling #14 has knob hardware. Provide a door with hardware, mounted between 34 and 48 inches high, that is operable with one hand and does not require tight grasping, pinching, or twisting of the wrist and requires no more than 5 pounds of force to operate. Lever-operated mechanisms, push-type mechanisms, and U-shaped handles are acceptable designs. Standards §§ 206.4, 206.5, 309.4, 404.2.7.

c. Toilet Rooms

i. Women’s

(1) The toilet room sign is not mounted on the wall adjacent to the latch side of the door. Provide a toilet room sign with raised and

Braille characters. Tactile signs shall be mounted on the wall adjacent to the latch side of the door or the nearest adjacent wall (except that signs can be mounted on the push side of doors with closers and without hold-open devices); mounted 48 inches minimum from floor to the baseline of the lowest tactile character and 60 inches maximum from the floor to the baseline of the highest tactile character; and located so that a clear floor space of at least 18 inches by 18 inches, centered on the tactile characters, is provided beyond the arc of any door's swing between the closed and 45 degrees open positions. If not all toilet rooms are accessible, provide signage with the International Symbol of Accessibility at all accessible toilet rooms. Standards §§ 216.2, 703.

- (2) The pressure required to open the entry door is 10 pounds. Provide a door that requires no more than 5 pounds of force to open (not including the initial force needed to overcome inertia, retracting bolts, etc.). Standards §§ 206.5, 404.2.9.
- (3) The entry door maneuvering clearance is obstructed by the trash receptacle on the pull side of the door. Provide maneuvering clearance at least 60 inches deep perpendicular to the doorway and at least 18 inches wide parallel to the doorway on the latch side. §§ 206.5, 404.2.4.1.
- (4) The toilet room door swings into the required clear floor space at the paper towel dispenser and the sanitary napkin dispenser. No door shall swing into the required clear floor space or clearance at any accessible fixture (*e.g.*, toilet, urinal, lavatory). Standards §§ 213.2, 603.2.3.
- (5) Insufficient turning space is provided within the toilet room. Provide an unobstructed turning space at least 60 inches in diameter or a T-shaped space complying with § 304.3.2. Standards §§ 213.2, 304.3, 603.2.1.
- (6) The toilet compartment door has an opening width of 27 inches. Provide a self-closing compartment door at least 32 inches wide either in the front partition or side partition farthest from the toilet. § 404.2.3.
- (7) The toilet stall does not allow diagonal approach to transfer space. Provide a toilet compartment door complying with § 404 except that, if the approach is to the latch side of the compartment door, clearance between the door side of the compartment and any obstruction shall be at least 42 inches. Doors shall be located in

the front partition or in the side wall or partition farthest from the toilet. If located in the front partition, the door opening shall be at least 4 inches from the side wall or partition farthest from the toilet. Where located in the side wall or partition, the door opening shall be at least 4 inches from the front partition. The door shall be self-closing, and a door pull complying with § 404.2.7 shall be placed on both sides of the door near the latch. Toilet compartment doors shall not swing into the minimum required compartment area. Standards §§ 213.3.1, 404, 604.8.1.2.

- (8) The closer end of the side grab bar at the toilet is mounted 13 inches from the rear wall and the bar is mounted 32 inches high. Provide a side grab bar that is at least 42 inches in overall length, with the far end mounted at least 54 inches from the rear wall, and with the closer end no more than 12 inches from the rear wall. Standards §§ 213.3.2, 604.5.1.
- (9) The closer end of the rear grab bar at the toilet is mounted 10 inches from the side wall. Provide a rear grab bar that is at least 36 inches long (except where wall space does not permit it due to the location of a recessed fixture, in which case the grab bar may be 24 inches long and centered on the toilet), extending 12 inches from the toilet centerline on one side and 24 inches from the toilet centerline on the other side (except where an administrative authority requires flush controls to be located in a position that conflicts with the location of the rear grab bar, in which case the bar may be split or shifted to the open side). Standards §§ 213.3.2, 604.5.2.

ii. Men's

- (1) The toilet room sign is not mounted on the wall adjacent to the latch side of the door. Provide a toilet room sign with raised and Braille characters. Tactile signs shall be mounted on the wall adjacent to the latch side of the door or the nearest adjacent wall (except that signs can be mounted on the push side of doors with closers and without hold-open devices); mounted 48 inches minimum from floor to the baseline of the lowest tactile character and 60 inches maximum from the floor to the baseline of the highest tactile character; and located so that a clear floor space of at least 18 inches by 18 inches, centered on the tactile characters, is provided beyond the arc of any door's swing between the closed and 45 degrees open positions. If not all toilet rooms are accessible, provide signage with the International Symbol of Accessibility at all accessible toilet rooms. Standards §§ 216.2, 703.

- (2) The pressure required to open the door entry is 15 pounds. Provide a door that requires no more than 5 pounds of force to open (not including the initial force needed to overcome inertia, retracting bolts, etc.). Standards §§ 206.5, 404.2.9.
- (3) The entry door maneuvering clearance is obstructed by the trash receptacle on the pull side of the door. Provide maneuvering clearance at least 60 inches deep perpendicular to the doorway and at least 18 inches wide parallel to the doorway. Standards §§ 206.5, 404.2.4.1.
- (4) The urinal rim is higher than 17 inches above the finished floor and the flush control is 54 inches above the finished floor. Provide a stall-type or a wall-hung urinal with a rim mounted 17 inches high or less; a depth of at least 13½ inches from the outer face to the rear of the urinal; a clear floor space at least 30 inches wide and 48 inches deep positioned for a forward approach; and a flush control between 15 and 48 inches high or an automatic flush. Standards §§ 213.3.3, 305, 308.2, 309.4, 605.
- (5) The toilet stall does not allow diagonal approach to transfer space. Provide a toilet compartment door complying with § 404 except that, if the approach is to the latch side of the compartment door, clearance between the door side of the compartment and any obstruction shall be at least 42 inches. Doors shall be located in the front partition or in the side wall or partition farthest from the toilet. If located in the front partition, the door opening shall be at least 4 inches from the side wall or partition farthest from the toilet. Where located in the side wall or partition, the door opening shall be at least 4 inches from the front partition. The door shall be self-closing, and a door pull complying with § 404.2.7 shall be placed on both sides of the door near the latch. Toilet compartment doors shall not swing into the minimum required compartment area. Standards §§ 213.3.1, 404, 604.8.1.2.
- (6) No accessible coat hook is provided. Provide a coat hook or towel hook between 15 and 48 inches high accompanied by clear floor space of 30 by 48 inches. Standards §§ 213.3.7, 305, 308, 603.4.
- (7) The closer end of the side grab bar at the toilet is mounted 13 inches from the rear wall. Provide a side grab bar that is at least 42 inches in overall length, with the far end mounted at least 54 inches from the rear wall, and with the closer end no more than 12 inches from the rear wall. Standards §§ 213.3.2, 604.5.1.

- (8) The closer end of the rear grab bar at the toilet is mounted at 9½ inches from the side wall. Provide a rear grab bar that is at least 36 inches long (except where wall space does not permit it due to the location of a recessed fixture, in which case the grab bar may be 24 inches long and centered on the toilet), extending 12 inches from the toilet centerline on one side and 24 inches from the toilet centerline on the other side (except where an administrative authority requires flush controls to be located in a position that conflicts with the location of the rear grab bar, in which case the bar may be split or shifted to the open side). Standards §§ 213.3.2, 604.5.2.

4. Within 9 months of entry of the Consent Decree, the County will complete the following modifications to **Child Support Services**, located at 2420 Sixth Street in Eureka.

a. Parking

- i. No designated van accessible parking space is provided. Provide a van accessible parking space that is a minimum of 132 inches wide and served by an access aisle at least 60 inches wide, or a minimum of 96 inches wide and served by an access aisle at least 96 inches wide; and designated by a vertical sign with the International Symbol of Accessibility and an additional “van accessible” sign mounted at least 60 inches high to the bottom of the signs (unless there are 4 or fewer total parking spaces, in which case, signage is not required). The space and access aisle shall contain no changes in level, with slopes and cross-slopes not exceeding 2.08%, and shall have surfaces that are firm, stable, and slip-resistant; and the access aisle shall be marked so as to discourage parking in it. Standards §§ 208, 302, 502.
- ii. The signage designating parking reserved for persons with disabilities is not mounted at each accessible space. At sites with 5 or more parking spaces, provide vertical signs with the International Symbol of Accessibility at all spaces designated as reserved for persons with disabilities, and, at van accessible parking spaces, provide an additional “van accessible” sign. Mount signs at least 60 inches high to the bottom of the sign. Standards §§ 208, 216.5, 502.6, 703.7.2.1.

- b. The reception counter protrudes into the walkway and is not detectable to a blind person using a cane. Unless protected by a cane detectable barrier, objects with their leading edges between 27 inches and 80 inches high shall not protrude into circulation paths more than 4 inches for wall-mounted elements, or 12 inches for free standing post- or pylon-mounted elements. Protruding objects (and cane-detectable barriers) shall not reduce the clear width of accessible routes or maneuvering spaces below minimum requirements. Standards §§ 206, 307.

- c. Offices
    - i. Secured meeting room - The pressure required to open the door is 10 pounds. Provide a door that requires no more than 5 pounds of force to open (not including the initial force needed to overcome inertia, retracting bolts, etc.). Standards §§ 206.5, 404.2.9.
    - ii. Non-secured meeting room - The pressure required to open the door is 10 pounds. Provide a door that requires no more than 5 pounds of force to open (not including the initial force needed to overcome inertia, retracting bolts, etc.). Standards §§ 206.5, 404.2.9.
  - d. Drinking Fountain
    - i. The drinking fountain has a spout that is 37 inches above the finished floor. Provide 50% of all drinking fountains on each floor or exterior site with a spout outlet between 38 and 43 inches high and 50% of all drinking fountains on each floor or exterior site with a spout outlet no more than 36 inches high that otherwise complies with the Standards. At least one of each type shall be provided. Standards §§ 211, 602.4, 602.7.
5. Within 9 months of entry of the Consent Decree, the County will complete the following modifications to the **McKinleyville Sheriff's Substation**, located at 1608 Pickett Street in McKinleyville.
- a. Parking
    - i. The designated accessible van parking space lacks the required signage. At sites with 5 or more parking spaces, provide vertical signs with the International Symbol of Accessibility at all spaces designated as reserved for persons with disabilities, and, at van accessible parking spaces, provide an additional "van accessible" sign. Mount signs at least 60 inches high to the bottom of the sign. Standards §§ 208, 216.5, 502.6, 703.7.2.1.
    - ii. The built-up curb ramp extends into the parking space access aisle. At each accessible parking space, provide an access aisle that is at least 60 inches wide, except at van accessible parking spaces that are less than 132 inches wide, in which case provide an access aisle at least 96 inches wide. All access aisles shall adjoin an accessible route; extend the full length of the parking space they serve; be marked so as to discourage parking in them; contain no changes in level, with slopes and cross-slopes not exceeding 2.08%; and have surfaces that are firm, stable, and slip-resistant. Standards §§ 208, 302, 502.
  - b. Counter - The counter is 43 inches high. Provide counters dispersed throughout the facility (dispersion is not required where only 1 counter is provided) on

accessible routes such that each counter has a portion extending the same depth as the counter top and no more than 36 inches high. If a parallel approach is provided, the accessible portion of the counter shall be at least 36 inches long (unless the entire counter is less than 36 inches high) and have clear floor space positioned for a parallel approach; if a forward approach is provided, the accessible portion of the counter shall be at least 30 inches long and have knee and toe space provided under the counter and clear floor space positioned for a forward approach. Standards §§ 227.3, 305, 306, 904.4.

6. Within 9 months of entry of the Consent Decree, the County will complete the following modifications to the **McKinleyville Library** located at 1606 Pickett Road in McKinleyville.

a. Toilet Rooms

i. Men's

- (1) The toilet room sign is not mounted on the wall adjacent to the latch side of the door more than 60 inches above the finished floor. Provide a toilet room sign with raised and Braille characters. Tactile signs shall be mounted on the wall adjacent to the latch side of the door or the nearest adjacent wall (except that signs can be mounted on the push side of doors with closers and without hold-open devices); mounted 48 inches minimum from floor to the baseline of the lowest tactile character and 60 inches maximum from the floor to the baseline of the highest tactile character; and located so that a clear floor space of at least 18 inches by 18 inches, centered on the tactile characters, is provided beyond the arc of any door's swing between the closed and 45 degrees open positions. If not all toilet rooms are accessible, provide signage with the International Symbol of Accessibility at all accessible toilet rooms. Standards §§ 216.2, 703.
- (2) The pressure required to open the door is 11 pounds. Provide a door that requires no more than 5 pounds of force to open (not including the initial force needed to overcome inertia, retracting bolts, etc.). Standards §§ 206.5, 404.2.9.
- (3) The toilet centerline is 19 inches from the side wall. Provide a toilet with its centerline between 16 and 18 inches from the near side wall. Standards §§ 213.3.2, 604.2.
- (4) No accessible coat hook is provided. Provide a coat hook or towel hook between 15 and 48 inches high accompanied by clear floor space of 30 by 48 inches. Standards §§ 213.3.7, 305, 308, 603.4.

ii. Women's

- (1) The toilet room sign is not mounted on the wall adjacent to the latch side of the door more than 60 inches above the finished floor. Provide a toilet room sign with raised and Braille characters. Tactile signs shall be mounted on the wall adjacent to the latch side of the door or the nearest adjacent wall (except that signs can be mounted on the push side of doors with closers and without hold-open devices); mounted 48 inches minimum from floor to the baseline of the lowest tactile character and 60 inches maximum from the floor to the baseline of the highest tactile character; and located so that a clear floor space of at least 18 inches by 18 inches, centered on the tactile characters, is provided beyond the arc of any door's swing between the closed and 45 degrees open positions. If not all toilet rooms are accessible, provide signage with the International Symbol of Accessibility at all accessible toilet rooms. Standards §§ 216.2, 703.
- (2) The toilet centerline is 20 inches from the side wall. Provide a toilet with its centerline between 16 and 18 inches from the near side wall. Standards §§ 213.3.2, 604.2.
- (3) No accessible coat hook is provided. Provide a coat hook or towel hook between 15 and 48 inches high accompanied by clear floor space of 30 by 48 inches. Standards §§ 213.3.7, 305, 308, 603.4.

7. Within 9 months of entry of the Consent Decree, the County will complete the following modifications to **Redwood Regional Development**, 520 E. Street in Eureka.

a. Men's

- i. The toilet room sign is not mounted on the wall adjacent to the latch side of the door. Provide a toilet room sign with raised and Braille characters. Tactile signs shall be mounted on the wall adjacent to the latch side of the door or the nearest adjacent wall (except that signs can be mounted on the push side of doors with closers and without hold-open devices); mounted 48 inches minimum from floor to the baseline of the lowest tactile character and 60 inches maximum from the floor to the baseline of the highest tactile character; and located so that a clear floor space of at least 18 inches by 18 inches, centered on the tactile characters, is provided beyond the arc of any door's swing between the closed and 45 degrees open positions. If not all toilet rooms are accessible, provide signage with the International Symbol of Accessibility at all accessible toilet rooms. Standards §§ 216.2, 703.
- ii. The pressure required to open the door is 7 pounds. Provide a door that

requires no more than 5 pounds of force to open (not including the initial force needed to overcome inertia, retracting bolts, etc.). Standards §§ 206.5, 404.2.9.

- iii. No accessible mirror is provided. Provide at least one mirror such that, if it is mounted above a lavatory or countertop, it is mounted with the bottom edge of the reflecting surface no more than 40 inches high; or, if it is not mounted above a lavatory or countertop, it is mounted with the bottom edge of the reflecting surface no more than 35 inches high. Standards §§ 213.2, 603.3.
- iv. The toilet flush control is on the closed side. Provide a flush control mounted on the “open” side of the toilet’s clear floor space, between 15 and 48 inches high, and requiring a maximum of 5 pounds of force to operate; or provide an automatic flush device. Standards §§ 213.3.2, 309.4, 604.6.
- v. No accessible coat hook is provided. Provide a coat hook or towel hook between 15 and 48 inches high accompanied by clear floor space of 30 by 48 inches. Standards §§ 213.3.7, 305, 308, 603.4.

b. Women’s

- i. The toilet room sign is not mounted on the wall adjacent to the latch side of the door. Provide a toilet room sign with raised and Braille characters. Tactile signs shall be mounted on the wall adjacent to the latch side of the door or the nearest adjacent wall (except that signs can be mounted on the push side of doors with closers and without hold-open devices); mounted 48 inches minimum from floor to the baseline of the lowest tactile character and 60 inches maximum from the floor to the baseline of the highest tactile character; and located so that a clear floor space of at least 18 inches by 18 inches, centered on the tactile characters, is provided beyond the arc of any door’s swing between the closed and 45 degrees open positions. If not all toilet rooms are accessible, provide signage with the International Symbol of Accessibility at all accessible toilet rooms. Standards §§ 216.2, 703.
- ii. The pressure required to open the door is 7 pounds. Provide a door that requires no more than 5 pounds of force to open (not including the initial force needed to overcome inertia, retracting bolts, etc.). Standards §§ 206.5, 404.2.9.
- iii. No accessible mirror is provided. Provide at least one mirror such that, if it is mounted above a lavatory or countertop, it is mounted with the bottom edge of the reflecting surface no more than 40 inches high; or, if it is not mounted above a lavatory or countertop, it is mounted with the bottom

edge of the reflecting surface no more than 35 inches high. Standards §§ 213.2, 603.3.

- iv. The toilet flush control is on the closed side. Provide a flush control mounted on the “open” side of the toilet’s clear floor space, between 15 and 48 inches high, and requiring a maximum of 5 pounds of force to operate; or provide an automatic flush device. Standards §§ 213.3.2, 309.4, 604.6.
- v. No accessible coat hook is provided. Provide a coat hook or towel hook between 15 and 48 inches high accompanied by clear floor space of 30 by 48 inches. Standards §§ 213.3.7, 305, 308, 603.4.

8. Within 15 months of entry of the Consent Decree, the County will complete the following modifications to **Social Services Building C**, 600 W. Clark in Eureka.

a. Parking

- i. The designated van accessible parking space and access aisle are not level. Provide designated accessible parking spaces and access aisles that contain no changes in level, with slopes and cross-slopes not exceeding 2.08%, with surfaces that are firm, stable, and slip-resistant. Standards §§ 208, 302, 502.4.

b. Accessible Route

- i. The entrance door pull side maneuvering space is obstructed by a planter. Provide a clear floor or ground space at least 48 inches deep perpendicular to the doorway and at least 24 wide parallel to the doorway on the latch side. Standards §§ 206.5, 404.2.4.1.

c. Offices

- i. The door to the conference room has an opening width of 29 inches. Provide a door with a clear opening at least 32 inches wide, measured between the face of the door and the opposite stop, when the door is open 90 degrees. Standards §§ 206.4, 206.5, 404.2.3.

d. Drinking Fountain

- i. No drinking fountain is provided for people who have difficulty bending or stooping. Provide 50% of all drinking fountains on each floor or exterior site with a spout outlet between 38 and 43 inches high and 50% of all drinking fountains on each floor or exterior site with a spout outlet no more than 36 inches high that otherwise complies with the Standards. At least one of each type shall be provided. Standards §§ 211, 602.4, 602.7.

e. Toilet Rooms

i. Women's

- (1) The paper towel dispenser controls are mounted 54 inches above the finished floor with a forward reach required. Operable parts and controls of this element shall be between 15 and 48 inches high and accompanied by clear floor space of 30 by 48 inches that allows a forward or parallel approach by a person using a wheelchair. Standards §§ 205.1, 305, 308.2, 308.3, 309.
- (2) The sanitary napkin dispenser controls are mounted 58 inches above the finished floor. Operable parts and controls of this element shall be between 15 and 48 inches high and accompanied by clear floor space of 30 by 48 inches that allows a forward or parallel approach by a person using a wheelchair. Standards §§ 205.1, 305, 308.2, 308.3, 309.
- (3) The toilet stall is not configured so as to be accessible. Provide an accessible toilet compartment at least 60 inches wide and at least 59 inches deep (or at least 56 inches deep with a wall-mounted toilet) such that all of the compartment's elements, including door, door hardware, toilet, size and arrangement, toe clearances, grab bars, controls, and dispensers, comply with the Standards. Standards §§ 213.3.1, 301.1, 404, 604, 604.8.1, 609.

9. Within 15 months of entry of the Consent Decree, the County will complete the following modifications to the **Mental Health - Child Youth and Family Services**, located at 1711 3<sup>rd</sup> Street in Eureka.

a. Parking

- i. No designated van accessible parking space or access aisle is provided and the pavement markings are not clear. Provide a van accessible parking space that is a minimum of 132 inches wide and served by an access aisle at least 60 inches wide, or a minimum of 96 inches wide and served by an access aisle at least 96 inches wide; and designated by a vertical sign with the International Symbol of Accessibility and an additional "van accessible" sign mounted at least 60 inches high to the bottom of the signs (unless there are 4 or fewer total parking spaces, in which case, signage is not required). The space and access aisle shall contain no changes in level, with slopes and cross-slopes not exceeding 2.08%, and shall have surfaces that are firm, stable, and slip-resistant; and the access aisle shall be marked so as to discourage parking in it. Standards §§ 208, 302, 502.

- b. Accessible Route
- i. The route from the parking lot into the building is not stable, firm or slip resistant and the surface is not level. To each area, feature, or element described, provide at least one accessible route that coincides with or is located in the same area as general circulation paths. The accessible route must have a minimum clear width of 36 inches (except that it may narrow to no less than 32 inches for a length of no more than 24 inches), or a minimum clear width of 42 inches if there is a U-turn around an obstruction less than 48 inches wide; have passing spaces at least every 200 feet; have a minimum clear headroom of 80 inches; have a surface that is firm, stable, and slip resistant; have, in the absence of a curb ramp, ramp, elevator, or platform lift, no level changes in excess of ½ inch vertically; have no level changes greater than ¼ inch vertically unless they are beveled with a slope no greater than 50%; and have a running slope no greater than 5% (or have been constructed as a fully accessible ramp) and a cross slope no greater than 2.08%. Standards §§ 206, 301.1, 401.1.
  - ii. The entrance has no level approach within the door's required maneuvering clearance. The floor or ground area within the door's required clearances shall have a slope no greater than 2.08%, or an automatic door opener with standby power or that remains open with the power off. All automatic door opener operating devices shall be easy to operate with one hand; shall not require tight grasping, pinching, or twisting of the wrist to operate; shall not require more than 5 pounds of force to operate; shall be mounted between 15 and 48 inches high on an accessible route; and shall be accompanied by a clear floor space that is 48 inches by 30 inches and is beyond the arc of the door's swing. Standards §§ 206.4, 305, 308, 309.4, 404.2.4.4, 404.3.5.
- c. No signage directing people with disabilities to the accessible toilet rooms is provided. Provide accessible directional signage with the International Symbol of Accessibility at inaccessible toilet rooms indicating the location of the nearest accessible toilet room, and provide accessible signage with the International Symbol of Accessibility at all accessible toilet rooms. Standards §§ 216.3, 216.8, 703.5, 703.7.2.1.
- d. Toilet Room - "Designated Accessible"
- i. No accessible toilet room sign is provided. Provide a toilet room sign with raised and Braille characters. Tactile signs shall be mounted on the wall adjacent to the latch side of the door or the nearest adjacent wall (except that signs can be mounted on the push side of doors with closers and without hold-open devices); mounted 48 inches minimum from floor to the baseline of the lowest tactile character and 60 inches maximum

from the floor to the baseline of the highest tactile character; and located so that a clear floor space of at least 18 inches by 18 inches, centered on the tactile characters, is provided beyond the arc of any door's swing between the closed and 45 degrees open positions. If not all toilet rooms are accessible, provide signage with the International Symbol of Accessibility at all accessible toilet rooms. Standards §§ 216.2, 703.

- ii. No accessible mirror is provided. Provide at least one mirror such that, if it is mounted above a lavatory or countertop, it is mounted with the bottom edge of the reflecting surface no more than 40 inches high; or, if it is not mounted above a lavatory or countertop, it is mounted with the bottom edge of the reflecting surface no more than 35 inches high. Standards §§ 213.2, 603.3.
- iii. The toilet seat cover dispenser is beyond required reach ranges. Operable parts and controls of this element shall be no more than 48 inches high for a forward reach, or no more than 44 inches high if over an obstruction between 20 and 25 inches deep (for a forward reach, obstructions may not be deeper than 25 inches and obstructions must allow knee space); or mounted not more than 48 inches high for a side reach, or no more than 46 inches high if over an obstruction between 10 and 24 inches deep (for a side reach, obstructions may not be deeper than 24 inches); and accompanied by clear floor space of 30 inches by 48 inches that allows a forward or parallel approach, respectively, by a person using a wheelchair. Standards §§ 205.1, 305, 308.2, 308.3.
- iv. The lavatory hot water pipes are not insulated or otherwise configured to protect against contact. Provide water supply and drain pipes insulated or otherwise configured to protect against contact. There shall be no sharp or abrasive surfaces underneath the lavatory or sink. Standards §§ 213.3.4, 606.5.
- v. The toilet seat is 16 inches above the finished floor. Provide a toilet with the top of the seat 17 to 19 inches high. The seat shall not be sprung to return to a lifted position. Standards §§ 213.3.2, 604.4.29.
- vi. No grab bars provided are provided. Provide a rear grab bar that is at least 36 inches long (except where wall space does not permit it due to the location of a recessed fixture, in which case the grab bar may be 24 inches long), extending 12 inches from the toilet centerline on one side and 24 inches on the other side (except where an administrative authority requires flush controls to be located in a position that conflicts with the location of the rear grab bar, in which case the bar may be split or shifted to the open side). Provide a side grab bar that is at least 42 inches in overall length, with the far end mounted at least 54 inches from the rear wall and the closer end no more than 12 inches from the rear wall. Grab bars shall be

mounted between 33 and 36 inches high to the top of the gripping surface; with a diameter between 1¼ and 2 inches (or, if the grab bar is not circular, a perimeter between 4 and 4¾ inches and cross-section dimensions of no more than 2 inches); with 1½ inches between the grab bar and the wall; and at least 1½ inches between the grab bar and any object projecting beside or below it and at least 12 inches between the grab bar and any object projecting above it. Grab bars shall also comply with requirements for surface hazards, fittings, and structural strength. Standards §§ 213.3.2, 604.5, 609.

10. Within 9 months of entry of the Consent Decree, the County will complete the following modifications to **Family Visitation Center**, located at 231 D Street in Eureka.

a. Parking

- i. No designated accessible van parking space is provided. Provide a van accessible parking space that is a minimum of 132 inches wide and served by an access aisle at least 60 inches wide, or a minimum of 96 inches wide and served by an access aisle at least 96 inches wide; and designated by a vertical sign with the International Symbol of Accessibility and an additional “van accessible” sign mounted at least 60 inches high to the bottom of the signs (unless there are 4 or fewer total parking spaces, in which case, signage is not required). The space and access aisle shall contain no changes in level, with slopes and cross-slopes not exceeding 2.08%, and shall have surfaces that are firm, stable, and slip-resistant; and the access aisle shall be marked so as to discourage parking in it. Standards §§ 208, 302, 502.

b. Single User Toilet Room

i. Women’s

- (1) The sign is not mounted on the wall adjacent to the latch side of the door. Provide a toilet room sign with raised and Braille characters. Tactile signs shall be mounted on the wall adjacent to the latch side of the door or the nearest adjacent wall (except that signs can be mounted on the push side of doors with closers and without hold-open devices); mounted 48 inches minimum from floor to the baseline of the lowest tactile character and 60 inches maximum from the floor to the baseline of the highest tactile character; and located so that a clear floor space of at least 18 inches by 18 inches, centered on the tactile characters, is provided beyond the arc of any door’s swing between the closed and 45 degrees open positions. If not all toilet rooms are accessible, provide signage with the International Symbol of Accessibility at all accessible toilet rooms. Standards §§ 216.2, 703.

- (2) The pressure required to open the entry door is 10 pounds. Provide a door that requires no more than 5 pounds of force to open (not including the initial force needed to overcome inertia, retracting bolts, etc.). Standards §§ 206.5, 404.2.9.
- (3) The entry door has insufficient clear floor space on the latch side in the pull direction of the door. Provide a maneuvering clearance at least 60 inches deep perpendicular to the doorway and at least 18 inches wide parallel to the doorway on the latch side. §§ 206.5, 404.2.4.1.
- (4) No accessible coat hook is provided. Provide a coat hook or towel hook between 15 and 48 inches high accompanied by clear floor space of 30 by 48 inches. Standards §§ 213.3.7, 305, 308, 603.4.
- (5) The toilet centerline is 19 inches from the side wall. Provide a toilet with its centerline between 16 and 18 inches from the near side wall. Standards §§ 213.3.2, 604.2.
- (6) The rear grab bar at the toilet is obstructed by the toilet tank. Provide grab bars that have at least 1½ inches between the grab bar and any object projecting beside or below it and at least 12 inches between the grab bar and any object projecting above it. Standards §§ 213.3.2, 604.5, 609.3.

ii. Men's

- (1) The entry door has insufficient clear floor space on the latch side in the pull direction. Provide a maneuvering clearance at least 60 inches deep perpendicular to the doorway and at least 18 inches wide parallel to the doorway on the latch side. §§ 206.5, 404.2.4.1.
- (2) Insufficient turning space is provided within the toilet room. Provide an unobstructed turning space at least 60 inches in diameter or a T-shaped space complying with § 304.3.2. Standards §§ 213.2, 304.3, 603.2.1.
- (3) The toilet centerline is 19 inches from the side wall. Provide a toilet with its centerline between 16 and 18 inches from the near side wall. Standards §§ 213.3.2, 604.2.
- (4) The toilet flush control is on the closed side. Provide a flush control mounted on the "open" side of the toilet's clear floor space, between 15 and 48 inches high, and requiring a maximum of 5 pounds of force to operate; or provide an automatic flush device.

Standards §§ 213.3.2, 309.4, 604.6.

- (5) The rear grab bar at the toilet is obstructed by the toilet tank. Provide grab bars that have at least 1½ inches between the grab bar and any object projecting beside or below it and at least 12 inches between the grab bar and any object projecting above it. Standards §§ 213.3.2, 604.5, 609.3.

11. Within 9 months of entry of the Consent Decree, the County will complete the following modifications to the **Probation Department**, located at 1105 Sixth Street in Eureka.
  - a. **Parking.** The parking reserved for persons with disabilities lacks required signage. At sites with 5 or more parking spaces, provide vertical signs with the International Symbol of Accessibility at all spaces designated as reserved for persons with disabilities, and, at van accessible parking spaces, provide an additional “van accessible” sign. Mount signs at least 60 inches high to the bottom of the sign. Standards §§ 208, 216.5, 502.6, 703.7.2.1.
  - b. **Accessible Route.**
    - i. The entrance into the building has a 3 inch change in level at the door threshold. Provide an accessible door with a threshold that is no more than ¼ inch high, or is between ¼ inch and ½ inch high (¾ inch high if the threshold is existing or altered) and is beveled with a slope no greater than 50%. Standards §§ 206.5, 302, 303, 404.2.5.
    - ii. The hallway entrance door to the program has knob hardware. Provide a door with hardware, mounted between 34 and 48 inches high, that is operable with one hand and does not require tight grasping, pinching, or twisting of the wrist and requires no more than 5 pounds of force to operate. Lever-operated mechanisms, push-type mechanisms, and U-shaped handles are acceptable designs. Standards §§ 206.4, 206.5, 309.4, 404.2.7.
  - c. **Single User Toilet Room**
    - i. The toilet room sign is not mounted on the wall adjacent to the latch side of the door with Braille and raised characters. Provide a toilet room sign with raised and Braille characters. Tactile signs shall be mounted on the wall adjacent to the latch side of the door or the nearest adjacent wall (except that signs can be mounted on the push side of doors with closers and without hold-open devices); mounted 48 inches minimum from floor to the baseline of the lowest tactile character and 60 inches maximum from the floor to the baseline of the highest tactile character; and located so that a clear floor space of at least 18 inches by 18 inches, centered on the tactile characters, is provided beyond the arc of any door’s swing

between the closed and 45 degrees open positions. If not all toilet rooms are accessible, provide signage with the International Symbol of Accessibility at all accessible toilet rooms. Standards §§ 216.2, 703.

- ii. The toilet centerline is 28 inches from the side wall. Provide a toilet with its centerline between 16 and 18 inches from the near side wall. Standards §§ 213.3.2, 604.2.
- iii. The toilet flush control is on the closed side. Provide a flush control mounted on the “open” side of the toilet’s clear floor space, between 15 and 48 inches high, and requiring a maximum of 5 pounds of force to operate; or provide an automatic flush device. Standards §§ 213.3.2, 309.4, 604.6.

12. Within 9 months of entry of the Consent Decree, the County will complete the following modifications to the **Rio Dell Library** located at 715 Wildwood Avenue in Rio Dell.

- a. **Parking.** The parking has no designated accessible parking. Provide a van accessible parking space that is a minimum of 132 inches wide and served by an access aisle at least 60 inches wide, or a minimum of 96 inches wide and served by an access aisle at least 96 inches wide; and designated by a vertical sign with the International Symbol of Accessibility and an additional “van accessible” sign mounted at least 60 inches high to the bottom of the signs (unless there are 4 or fewer total parking spaces, in which case, signage is not required). The space and access aisle shall contain no changes in level, with slopes and cross-slopes not exceeding 2.08%, and shall have surfaces that are firm, stable, and slip-resistant; and the access aisle shall be marked so as to discourage parking in it. Standards §§ 208, 302, 502.
- b. **Accessible Route**
  - i. The route from the parking lot to the building is not stable, firm, or slip resistant. To each area, feature, or element described, provide at least one accessible route that coincides with or is located in the same area as general circulation paths. The accessible route must have a minimum clear width of 36 inches (except that it may narrow to no less than 32 inches for a length of no more than 24 inches), or a minimum clear width of 42 inches if there is a U-turn around an obstruction less than 48 inches wide; have passing spaces at least every 200 feet; have a minimum clear headroom of 80 inches; have a surface that is firm, stable, and slip resistant; have, in the absence of a curb ramp, ramp, elevator, or platform lift, no level changes in excess of ½ inch vertically; have no level changes greater than ¼ inch vertically unless they are beveled with a slope no greater than 50%; and have a running slope no greater than 5% (or have been constructed as a fully accessible ramp) and a cross slope no greater than 2.08%. Standards §§ 206, 301.1, 401.1.

- ii. The ramp surface at the bottom is not stable, firm, or slip resistant; the landing at the change in direction is 53 inches by 40 inches; and the handrails are mounted at 41 inches above the finished floor. Provide a ramp that is at least 36 inches wide between handrails, with a slope not exceeding 8.33% and a cross slope not exceeding 2.08%; with level landings at least as wide as the ramp and 60 inches long at the top and bottom of every ramp run; with level landings at least 60 inches by 60 inches when the ramp changes direction; and with no changes in level other than the slope and cross-slope. The ramp shall have no run containing a rise greater than 30 inches. On each side of ramp runs and landings, provide edge protection that consists of either an extended ground surface at least 12 inches beyond the edge of the surface of the ramp or landing, or a curb or barrier that prevents the passage of a 4 inch diameter sphere where any part of the sphere is within 4 inches of the surface. On both sides of ramps with rises greater than 6 inches, provide handrails that have a diameter between 1¼ and 2 inches or a perimeter between 4 inches and 6¼ inches and a cross section of no more than 2¼ inches such that the handrails are continuous along the full length of the ramp run. Inside handrails on switchbacks or doglegs shall be continuous between runs; handrails shall have a continuous gripping surface extending at least 12 inches beyond the top and bottom of the ramp parallel with the ground surface; extensions shall return to the wall, guard, or landing surface (or continue on as handrails); handrails shall not rotate within their fittings; handrails shall be mounted at a consistent height between 34 inches and 38 inches above the ramp surface and at least 1½ inches from the wall; gripping surfaces and adjacent surfaces shall be free of sharp or abrasive elements and have rounded edges; and gripping surfaces shall not be obstructed along their tops or sides and the bottoms shall not be obstructed for more than 20% of their length and have no horizontal projections occurring closer than 1½ inches from the bottom of the gripping surface (except that the distance between horizontal projections and the bottom of the gripping surface can be reduced by ⅛ inch for each ½ inch of handrail perimeter over 4 inches). If the ramp is subject to wet conditions, landings shall be designed to prevent the accumulation of water. Standards §§ 206.2, 405, 505.

13. Within 9 months of entry of the Consent Decree, the County will complete the following modifications to the **Trinidad Library**, located at 380 Janis Court in Trinidad.

a. Parking

- i. The parking lot has no access aisles. At each accessible parking space, provide an access aisle that is at least 60 inches wide, except at van accessible parking spaces that are less than 132 inches wide, in which case provide an access aisle at least 96 inches wide. All access aisles shall

adjoin an accessible route; extend the full length of the parking space they serve; be marked so as to discourage parking in them; contain no changes in level, with slopes and cross-slopes not exceeding 2.08%; and have surfaces that are firm, stable, and slip-resistant. Standards §§ 208, 302, 502.

- ii. The designated accessible van parking space lacks the required signage. At sites with 5 or more parking spaces, provide vertical signs with the International Symbol of Accessibility at all spaces designated as reserved for persons with disabilities, and, at van accessible parking spaces, provide an additional “van accessible” sign. Mount signs at least 60 inches high to the bottom of the sign. Standards §§ 208, 216.5, 502.6, 703.7.2.1.

b. Accessible Route

- i. Signage indicating the accessible route to the accessible entrance is not provided. Provide accessible directional signage at inaccessible entrances directing users to the accessible entrance, and provide accessible signage with the International Symbol of Accessibility at all permanent accessible entrances. Standards §§ 216.6, 703.5, 703.7.2.1

14. Within 9 months of entry of the Consent Decree, the County will complete the following modifications to the **SCOP Office** located at 76 Willow Road in Willow Creek.

- a. No designated accessible van parking space is provided. Provide a van accessible parking space that is a minimum of 132 inches wide and served by an access aisle at least 60 inches wide, or a minimum of 96 inches wide and served by an access aisle at least 96 inches wide; and designated by a vertical sign with the International Symbol of Accessibility and an additional “van accessible” sign mounted at least 60 inches high to the bottom of the signs (unless there are 4 or fewer total parking spaces, in which case, signage is not required). The space and access aisle shall contain no changes in level, with slopes and cross-slopes not exceeding 2.08%, and shall have surfaces that are firm, stable, and slip-resistant; and the access aisle shall be marked so as to discourage parking in it. Standards §§ 208, 302, 502.
- b. The ramp has no edge protection; no level landing at the top; the handrail height is not between 34 inches and 38 inches; and there are no 12 inch handrail extensions at the top or bottom. Provide a ramp that is at least 36 inches wide between handrails, with a slope not exceeding 8.33% and a cross slope not exceeding 2.08%; with level landings at least as wide as the ramp and 60 inches long at the top and bottom of every ramp run; with level landings at least 60 inches by 60 inches when the ramp changes direction; and with no changes in level other than the slope and cross-slope. The ramp shall have no run containing a rise greater than 30 inches. On each side of ramp runs and landings, provide edge protection that consists of either an extended ground surface at least 12

inches beyond the edge of the surface of the ramp or landing, or a curb or barrier that prevents the passage of a 4 inch diameter sphere where any part of the sphere is within 4 inches of the surface. On both sides of ramps with rises greater than 6 inches, provide handrails that have a diameter between 1¼ and 2 inches or a perimeter between 4 inches and 6¼ inches and a cross section of no more than 2¼ inches such that the handrails are continuous along the full length of the ramp run. Inside handrails on switchbacks or doglegs shall be continuous between runs; handrails shall have a continuous gripping surface extending at least 12 inches beyond the top and bottom of the ramp parallel with the ground surface; extensions shall return to the wall, guard, or landing surface (or continue on as handrails); handrails shall not rotate within their fittings; handrails shall be mounted at a consistent height between 34 inches and 38 inches above the ramp surface and at least 1½ inches from the wall; gripping surfaces and adjacent surfaces shall be free of sharp or abrasive elements and have rounded edges; and gripping surfaces shall not be obstructed along their tops or sides and the bottoms shall not be obstructed for more than 20% of their length and have no horizontal projections occurring closer than 1½ inches from the bottom of the gripping surface (except that the distance between horizontal projections and the bottom of the gripping surface can be reduced by ⅛ inch for each ½ inch of handrail perimeter over 4 inches). If the ramp is subject to wet conditions, landings shall be designed to prevent the accumulation of water. Standards §§ 206.2, 405, 505.

15. Within 9 months of entry of the Consent Decree, the County will complete the following modifications to the **Willow Creek Library** located at the intersection of Highway 299 and 96 in Willow Creek.
  - a. The surface of the route from the parking lot to the building entrance is not stable, firm, and slip resistant. To each area, feature, or element described, provide at least one accessible route that coincides with or is located in the same area as general circulation paths. The accessible route must have a minimum clear width of 36 inches (except that it may narrow to no less than 32 inches for a length of no more than 24 inches), or a minimum clear width of 42 inches if there is a U-turn around an obstruction less than 48 inches wide; have passing spaces at least every 200 feet; have a minimum clear headroom of 80 inches; have a surface that is firm, stable, and slip resistant; have, in the absence of a curb ramp, ramp, elevator, or platform lift, no level changes in excess of ½ inch vertically; have no level changes greater than ¼ inch vertically unless they are beveled with a slope no greater than 50%; and have a running slope no greater than 5% (or have been constructed as a fully accessible ramp) and a cross slope no greater than 2.08%. Standards §§ 206, 301.1, 401.1.
  - b. The entry door has knob hardware. Provide a door with hardware, mounted between 34 and 48 inches high, that is operable with one hand and does not require tight grasping, pinching, or twisting of the wrist and requires no more than 5 pounds of force to operate. Lever-operated mechanisms, push-type mechanisms, and U-shaped handles are acceptable designs. Standards §§ 206.4,

206.5, 309.4, 404.2.7.

- c. The free standing drinking fountain lacks knee space. Provide a drinking fountain with a clear floor space of at least 30 inches by 48 inches (36 inches by 48 inches if the unit is in an alcove more than 24 inches deep) positioned for a forward approach and centered on the unit. Knee clearance shall be at least 11 inches deep at 9 inches high and at least 8 inches deep at 27 inches high. Standards §§ 211, 305, 306, 602.2.
  - d. The toilet room contains a number of inaccessible elements and is not accessible to people with disabilities. Provide an accessible toilet room such that all of the room's elements, including signage, door, door hardware, clear floor space, toilet, stall size and arrangement (if any), urinal (if provided), grab bars, lavatory, mirror, controls, and dispensers, comply with the Standards. Standards §§ 204, 205, 206, 213, 216, 225, 301.1, 401.1, 601.1, 703, 811.
16. Within 15 months of entry of this Consent Decree, the County will complete the following modifications to the **Blue Lake Library** located at 111 Greenwood Avenue in Blue Lake.
- a. The tables in the library do not provide sufficient knee space. At least 5% (but no fewer than 1) of dining or work surfaces shall be available for use by people with mobility disabilities. Each accessible dining or work surface shall be on an accessible route; with clear floor space 30 inches wide by 48 inches deep positioned for a forward approach; with knee clearance at least 11 inches deep at 9 inches high and at least 8 inches deep at 27 inches high; and with a dining or work surface between 28 inches and 34 inches high. They shall be distributed throughout the facility, if applicable. Standards §§ 226, 305, 306, 902.
  - b. Single User Toilet Room
    - i. The toilet room sign is not mounted on the wall adjacent to the latch side of the door and lack Braille and raised characters. Provide a toilet room sign with raised and Braille characters. Tactile signs shall be mounted on the wall adjacent to the latch side of the door or the nearest adjacent wall (except that signs can be mounted on the push side of doors with closers and without hold-open devices); mounted 48 inches minimum from floor to the baseline of the lowest tactile character and 60 inches maximum from the floor to the baseline of the highest tactile character; and located so that a clear floor space of at least 18 inches by 18 inches, centered on the tactile characters, is provided beyond the arc of any door's swing between the closed and 45 degrees open positions. If not all toilet rooms are accessible, provide signage with the International Symbol of Accessibility at all accessible toilet rooms. Standards §§ 216.2, 703.
    - ii. The lavatory faucet hardware requires tight grasping, pinching, or twisting

of the wrist. Provide a lavatory with a faucet that can be operated with no more than 5 pounds of force and can be used with one hand and without tight grasping, pinching, or twisting of the wrist (lever-operated, push-type, and electronically controlled mechanisms are examples of acceptable designs). Hand-operated metering faucets shall remain open for at least 10 seconds. Standards §§ 213.3.4, 309.4, 606.4.

- iii. The toilet flush control is on the closed side. Provide a flush control mounted on the “open” side of the toilet’s clear floor space, between 15 and 48 inches high, and requiring a maximum of 5 pounds of force to operate; or provide an automatic flush device. Standards §§ 213.3.2, 309.4, 604.6.
  - iv. The closer end of the side grab bar at the toilet is mounted 14.5 inches from the rear wall. Provide a side grab bar that is at least 42 inches in overall length, with the far end mounted at least 54 inches from the rear wall, and with the closer end no more than 12 inches from the rear wall. Standards §§ 213.3.2, 604.5.1.
  - v. The required clear floor space at the toilet is obstructed by a trash receptacle. Provide clearance at the toilet that is at least 60 inches wide and 56 inches deep. This clearance may overlap with the toilet, grab bars, dispensers, sanitary napkin disposal, coat hooks, shelves, accessible routes, clear floor space and clearances for other fixtures, and turning space; but no other fixtures or obstructions, including lavatories, may be located within this clearance. Standards §§ 213.3.2, 604.3.
  - vi. The lavatory clear floor space is obstructed by boxes. Provide a lavatory with clear floor space at least 30 inches wide by 48 inches deep positioned for a forward approach. Standards §§ 213.3.4, 305, 606.
- c. The running slope of the ramp is 14.2%; the cross-slope is 2.5%; handrails are not provided on both sides; and the handrail provided is not between 34” and 38” high; lacks 12 inch handrail extensions at the top and bottom; and the handrail does not return smoothly to the wall or post. Provide a ramp that is at least 36 inches wide between handrails, with a slope not exceeding 8.33% and a cross slope not exceeding 2.08%; with level landings at least as wide as the ramp and 60 inches long at the top and bottom of every ramp run; with level landings at least 60 inches by 60 inches when the ramp changes direction; and with no changes in level other than the slope and cross-slope. The ramp shall have no run containing a rise greater than 30 inches. On each side of ramp runs and landings, provide edge protection that consists of either an extended ground surface at least 12 inches beyond the edge of the surface of the ramp or landing, or a curb or barrier that prevents the passage of a 4 inch diameter sphere where any part of the sphere is within 4 inches of the surface. On both sides of ramps with rises greater than 6 inches, provide handrails that have a diameter between 1¼ and 2 inches or

a perimeter between 4 inches and 6¼ inches and a cross section of no more than 2¼ inches such that the handrails are continuous along the full length of the ramp run. Inside handrails on switchbacks or doglegs shall be continuous between runs; handrails shall have a continuous gripping surface extending at least 12 inches beyond the top and bottom of the ramp parallel with the ground surface; extensions shall return to the wall, guard, or landing surface (or continue on as handrails); handrails shall not rotate within their fittings; handrails shall be mounted at a consistent height between 34 inches and 38 inches above the ramp surface and at least 1½ inches from the wall; gripping surfaces and adjacent surfaces shall be free of sharp or abrasive elements and have rounded edges; and gripping surfaces shall not be obstructed along their tops or sides and the bottoms shall not be obstructed for more than 20% of their length and have no horizontal projections occurring closer than 1½ inches from the bottom of the gripping surface (except that the distance between horizontal projections and the bottom of the gripping surface can be reduced by ⅛ inch for each ½ inch of handrail perimeter over 4 inches). If the ramp is subject to wet conditions, landings shall be designed to prevent the accumulation of water. Standards §§ 206.2, 405, 505.

d. Parking

- i. No designated van accessible parking space is provided. Provide a van accessible parking space that is a minimum of 132 inches wide and served by an access aisle at least 60 inches wide, or a minimum of 96 inches wide and served by an access aisle at least 96 inches wide; and designated by a vertical sign with the International Symbol of Accessibility and an additional “van accessible” sign mounted at least 60 inches high to the bottom of the signs (unless there are 4 or fewer total parking spaces, in which case, signage is not required). The space and access aisle shall contain no changes in level, with slopes and cross-slopes not exceeding 2.08%, and shall have surfaces that are firm, stable, and slip-resistant; and the access aisle shall be marked so as to discourage parking in it. Standards §§ 208, 302, 502.
- ii. The parking reserved for persons with disabilities lacks required signage. At all spaces designated as reserved for persons with disabilities, provide vertical signs with the International Symbol of Accessibility located such that they cannot be obstructed by parked vehicles. Standards §§ 4.6.4, 4.30.7(1). At sites with 5 or more parking spaces, provide vertical signs with the International Symbol of Accessibility at all spaces designated as reserved for persons with disabilities, and, at van accessible parking spaces, provide an additional “van accessible” sign. Mount signs at least 60 inches high to the bottom of the sign. Standards §§ 208, 216.5, 502.6, 703.7.2.1.
- iii. One of the designated accessible parking spaces is not located on the

shortest accessible route to the accessible facility entrance. Provide accessible parking that is located on the shortest accessible route to an accessible pedestrian entrance to the facility. Standards § 208.3.

17. Within 9 months of entry of the Consent Decree, the County will complete the following modifications to the **Public Health (WIC) Office** located at 1108 Main Street in Fortuna.
  - a. Accessible Route. The entrance door lacks sufficient clear floor space on the pull side. Provide maneuvering clearance at least 60 inches deep perpendicular to the doorway and at least 18 inches wide parallel to the doorway on the latch side of the door. Standards §§ 206.5, 404.2.4.1.